

# CR COLLEGE OF THE REDWOODS

## SUBSTITUTION REQUEST FORM

Contractor Name: MC MURRAY & SONS  
 Contract #: 707-443-3088

RFS # \_\_\_\_\_ Date: \_\_\_\_\_  
 DSA Application #: 01-119705  
 Campus: COLLEGE OF THE REDWOODS, EUREKA  
 Project No., Name: PE REPLACEMENT

Contractor pursuant to General Conditions submits the proposed items. If the District accepts such items so described, the undersigned may furnish such item with all necessary labor, materials, equipment and incidentals to perform and complete the Work.

Item No.	SPECIFIED ITEM OR DRAWING	SPECIFICATION SECTION	PROPOSED SUBSTITUTION (and name of Subcontractor if different)
	<u>PVC MEMBRANE</u>	<u>075419</u>	<u>DUROLAST PVC</u>

### CERTIFICATION

Under penalty of perjury under the Laws of California, I certify that the proposed substitution will be readily available, perform adequately the functions and achieve the results called for by the design concept, be similar in substance to that specified, and be suited to the same use as that specified in Contract Documents.

Contractor: MC MURRAY & SONS SACHIO TANUMA [Signature] 7-25-2024  
(Please print name of company) Name and Title (print/type) Contractor Authorized Representative Date

A. Does the substitution affect dimensions shown on Drawings?  
NO

B. Will the undersigned pay for changes to the building design, including engineering and detailing costs caused by the requested substitution?  
CHANGES NOT REQUIRED

C. What effect does the substitution have on other trades?  
NONE

D. Will substitution cause change to Project Schedule, or to critical delivery dates? Add? Shorten?  
EASIER TO GET

E. Differences between proposed substitution and specified item?  
DIFFERENT MANUFACTOR

F. What is the Cost Differential including all mark-ups?  
SAME

G. Are Manufacturer's guarantees for the proposed item the same as for item specified? Explain differences.  
SAME

H. The undersigned accepts full responsibility for delays caused by redesign of other items of the Work necessitated by substitution.  
YES

I. The undersigned states that the function, appearance and quality are equivalent or superior to the specified item.  
YES

<b>A/E Response:</b>	<b>District Representative Response:</b>	<b>tBP/ARCHITECTURE</b>
<input type="radio"/> Accepted	<input type="radio"/> Accepted	<input type="checkbox"/> No Exception Taken
<input type="radio"/> Not Accepted	<input type="radio"/> Not Accepted	<input type="checkbox"/> Rejected
<input checked="" type="radio"/> Accepted As Noted	<input type="radio"/> Accepted As Noted	<input checked="" type="checkbox"/> Make Corrections Noted
<input type="radio"/> Received Too Late	<input type="radio"/> Received Too Late	<input checked="" type="checkbox"/> Revise and Resubmit
BY: <u>JR</u> Date: <u>8/20/24</u>	BY: _____ Date: _____	By <u>JR</u> Date <u>8/20/24</u>

These drawings have been reviewed by the Architect solely as an aid to the General Contractor. The accuracy of these drawings and their conformity to the Plans and Specifications are the responsibility of the General Contractor. Verify all dimensions at the jobsite. Deviations from Drawings and Specifications shall be called to the Architect's attention in writing.

\* SAME MATERIAL USED ON APPLIED TECHNOLOGY BUILDING

- Side by side comparison not provided
- Refer to Specification 01 62 00 Product Options for further requirements

## SUBSTITUTION REQUEST FORM

Contractor Name: _____
Contract #: _____

RFS # \_\_\_\_\_ Date: 7/24/2024

DSA Application #: \_\_\_\_\_

Campus: \_\_\_\_\_

Project No., Name: \_\_\_\_\_

Contractor pursuant to General Conditions submits the proposed items. If the District accepts such items so described, the undersigned may furnish such item with all necessary labor, materials, equipment and incidentals to perform and complete the Work.

Item No.	SPECIFIED ITEM OR DRAWING	SPECIFICATION SECTION	PROPOSED SUBSTITUTION (and name of Subcontractor if different)
1	Classic HD 2.25" by FieldTurf	09 62 53 2.2A and 2.3A	AllSport Diamond 2.25" 48oz

**CERTIFICATION**

Under penalty of perjury under the Laws of California, I certify that the proposed substitution will be readily available, perform adequately the functions and achieve the results called for by the design concept, be similar in substance to that specified, and be suited to the same use as that specified in Contract Documents.

Contractor: Valley Precision Grading, Inc.      Lawrence Hamocon, VP Operations           7/24/2024

(Please print name of company)      Name and Title (print/type)      Contractor Authorized Representative      Date

A. Does the substitution affect dimensions shown on Drawings?  No
B. Will the undersigned pay for changes to the building design, including engineering and detailing costs caused by the requested substitution?  No because no changes to any of those will be required.
C. What effect does the substitution have on other trades?  No affect.
D. Will substitution cause change to Project Schedule, or to critical delivery dates? Add ? Shorten ?  No affect.
E. Differences between proposed substitution and specified item?  Manufacture of and certified installation company. We are the same team providing the turf and install on the stadium field.
F. What is the Cost Differential including all mark-ups?  No increase in cost.
G. Are Manufacturer's guarantees for the proposed item the same as for item specified? Explain differences.  Yes, similar 8-year warranty and exactly the same on the stadium field as we are the team providings that system and install.
H. The undersigned accepts full responsibility for delays caused by redesign of other items of the Work necessitated by substitution.  Yes but no delays will come from utilizing our system.
I. The undersigned states that the function, appearance and quality are equivalent or superior to the specified item.  Yes, our system exceeds the specified manufactures turf system and design intent.

<p><b>A/E Response:</b></p> <p><input type="radio"/> Accepted</p> <p><input checked="" type="radio"/> Not Accepted</p> <p><input type="radio"/> Accepted As Noted</p> <p><input type="radio"/> Received Too Late</p> <p>BY: <u>JR</u>      Date: <u>8/20/24</u></p>	<p><b>District Representative Response:</b></p> <p><input type="radio"/> Accepted</p> <p><input type="radio"/> Not Accepted</p> <p><input type="radio"/> Accepted As Noted</p> <p><input type="radio"/> Received Too Late</p> <p>By: _____      Date: _____</p>
<p><b>IBP/ARCHITECTURE</b></p> <p><input type="checkbox"/> No Exception Taken      <input type="checkbox"/> Make Corrections Noted</p> <p><input checked="" type="checkbox"/> Rejected      <input type="checkbox"/> Revise and Resubmit</p> <p>By: <u>JR</u>      Date: <u>8/20/24</u></p> <p style="font-size: x-small;">These drawings have been reviewed by the Architect solely as an aid to the General Contractor. The accuracy of these drawings and their conformity to the Plans and Specifications are the responsibility of the General Contractor. Verify all dimensions at the jobsite. Deviations from Drawings and Specifications shall be called to the Architect's attention in writing.</p>	

- Project specification is for interior turf not exterior - appropriate product not submitted
- Side by side comparison not provided
- Refer to Specification 01 62 00 Product Options for further requirements



## SUBSTITUTION REQUEST FORM

Contractor Name: _____
Contract #: _____

RFS # \_\_\_\_\_ Date: 8/9/24

DSA Application #: \_\_\_\_\_

Campus: \_\_\_\_\_

Project No., Name: \_\_\_\_\_

Contractor pursuant to General Conditions submits the proposed items. If the District accepts such items so described, the undersigned may furnish such item with all necessary labor, materials, equipment and incidentals to perform and complete the Work.

Item No.	SPECIFIED ITEM OR DRAWING	SPECIFICATION SECTION	PROPOSED SUBSTITUTION (and name of Subcontractor if different)
	Wood Flooring	096466 Wood Gymnasium Flooring	Tarkett Sport Omnisport (style Multi-Use/ PurePlay or other)

**CERTIFICATION**

Under penalty of perjury under the Laws of California, I certify that the proposed substitution will be readily available, perform adequately the functions and achieve the results called for by the design concept, be similar in substance to that specified, and be suited to the same use as that specified in Contract Documents.

Contractor: North Coast Floor & Tile                      Jason, General Manager                      8/9/24

(Please print name of company)                      Name and Title (print/type)                      Contractor Authorized Representative                      Date

<p>A. Does the substitution affect dimensions shown on Drawings? No</p>
<p>B. Will the undersigned pay for changes to the building design, including engineering and detailing costs caused by the requested substitution? None needed...</p>
<p>C. What effect does the substitution have on other trades? Negligible...</p>
<p>D. Will substitution cause change to Project Schedule, or to critical delivery dates? Add ? Shorten ? This will shorten overall project timeline and allow other trades to work in the area quicker.</p>
<p>E. Differences between proposed substitution and specified item? One is "real wood" the other is a synthetic alternative engineered to perform like wood.</p>
<p>F. What is the Cost Differential including all mark-ups? Not sure, because we haven't bid the wood.</p>
<p>G. Are Manufacturer's guarantees for the proposed item the same as for item specified? Explain differences. This Tarkett Omnisport has a 25 yr written warranty. Wood does not, the finish will have a guarantee, but it isn't much.</p>
<p>H. The undersigned accepts full responsibility for delays caused by redesign of other items of the Work necessitated by substitution. Of course... this process will be faster than the originally proposed.</p>
<p>I. The undersigned states that the function, appearance and quality are equivalent or superior to the specified item. Yes...</p>

<p><b>A/E Response:</b></p> <p><input type="radio"/> Accepted</p> <p><input checked="" type="radio"/> Not Accepted</p> <p><input type="radio"/> Accepted As Noted</p> <p><input checked="" type="radio"/> Received Too Late</p> <p>BY: <u>JR</u>                      Date: <u>8/20/24</u></p>	<p><b>District Representative Response:</b></p> <p><input type="radio"/> Accepted</p> <p><input type="radio"/> Not Accepted</p> <p><input type="radio"/> Accepted As Noted</p> <p><input type="radio"/> Received Too Late</p> <p>By: _____                      Date: _____</p>
<p><b>IBP/ARCHITECTURE</b></p> <p><input type="checkbox"/> No Exception Taken                      <input type="checkbox"/> Make Corrections Noted</p> <p><input checked="" type="checkbox"/> Rejected                      <input type="checkbox"/> Revise and Resubmit</p> <p>By: <u>JR</u>                      Date: <u>8/20/24</u></p> <p style="font-size: small;">These drawings have been reviewed by the Architect solely as an aid to the General Contractor. The accuracy of these drawings and their conformity to the Plans and Specifications are the responsibility of the General Contractor. Verify all dimensions at the jobsite. Deviations from Drawings and Specifications shall be called to the Architect's attention in writing.</p> <p><b>Gym flooring to be wood.</b></p>	





## SUBSTITUTION REQUEST FORM

Contractor Name: <u>Sierra School Equipment Company</u>
Contract #:

RFS # \_\_\_\_\_ Date: \_\_\_\_\_

DSA Application #: \_\_\_\_\_

Campus: \_\_\_\_\_

Project No., Name: \_\_\_\_\_

Contractor pursuant to General Conditions submits the proposed items. If the District accepts such items so described, the undersigned may furnish such item with all necessary labor, materials, equipment and incidentals to perform and complete the Work.

Item No.	SPECIFIED ITEM OR DRAWING	SPECIFICATION SECTION	PROPOSED SUBSTITUTION (and name of Subcontractor if different)
	Telescopic Bleachers	12 66 13 - Telescopic Seating	Irwin Seating Company VersaTract

### CERTIFICATION

Under penalty of perjury under the Laws of California, I certify that the proposed substitution will be readily available, perform adequately the functions and achieve the results called for by the design concept, be similar in substance to that specified, and be suited to the same use as that specified in Contract Documents.

Contractor: <u>Sierra School Equipment Company</u>	<u>Kevin McDermott</u>	<i>Kevin R. McDermott</i>	<u>8/8/2024</u>
(Please print name of company)	Name and Title (print/type)	Contractor Authorized Representative	Date

<b>A. Does the substitution affect dimensions shown on Drawings?</b>  There are subtle differences in the dimensions of the bleacher system. For example, Irwin's rise is 10" compared to Hussey's rise of 9-5/8".
<b>B. Will the undersigned pay for changes to the building design, including engineering and detailing costs caused by the requested substitution?</b>  No
<b>C. What effect does the substitution have on other trades?</b>  None
<b>D. Will substitution cause change to Project Schedule, or to critical delivery dates? Add ? Shorten ?</b>  No
<b>E. Differences between proposed substitution and specified item?</b>  See Attached
<b>F. What is the Cost Differential including all mark-ups?</b>  Not applicable
<b>G. Are Manufacturer's guarantees for the proposed item the same as for item specified? Explain differences.</b>  Yes, equal warranty. 10 year for understructure, 5 year for other components (wood, plastic, electrical), and 1 year for upholstered components.
<b>H. The undersigned accepts full responsibility for delays caused by redesign of other items of the Work necessitated by substitution.</b>  No
<b>I. The undersigned states that the function, appearance and quality are equivalent or superior to the specified item.</b>  Yes

<b>A/E Response:</b> <input type="radio"/> Accepted <input checked="" type="radio"/> Not Accepted <input type="radio"/> Accepted As Noted <input checked="" type="radio"/> Received Too Late BY: <u>JR</u> Date: <u>8/20/24</u>	<b>District Representative Response:</b> <input type="radio"/> Accepted <input type="radio"/> Not Accepted <input type="radio"/> Accepted As Noted <input type="radio"/> Received Too Late By: _____ Date: _____
--	---

**IBP/ARCHITECTURE**

No Exception Taken      Make Corrections Noted  
 Rejected      Revise and Resubmit

By: JR Date: 8/20/24

These drawings have been reviewed by the Architect solely as an aid to the General Contractor. The accuracy of these drawings and their conformity to the Plans and Specifications are the responsibility of the General Contractor. Verify all dimensions at the jobsite. Deviations from Drawings and Specifications shall be called to the Architect's attention in writing.

- Media Platforms not addressed
- Familiarity with DSA deferred submittal process not addressed
- Refer to Specification 01 62 00 Product Options for further requirements